

平成24年度 臨時水質検査結果

原水・浄水

検査項目			2-MIB	
採水日時			原水 (ng/L)	浄水 (ng/L)
月	日	時		
9	18	10:00	3	3
9	19	16:00	3	4
9	20	10:00		6
9	20	18:00	6	
9	21	18:00	9	3
9	22	17:00	14	3
9	23	16:50		12
9	23	22:30	110	
9	24	21:30		15
9	24	22:30	170	
9	25	6:30	200	
9	25	22:00		26
9	26	22:00	240	29
9	27	5:40		57
9	27	22:00	220	
9	28	13:00	280	
9	28	17:00		48
9	29	5:00	220	
9	29	7:30		26
9	30	13:00		25
9	30	22:00	270	
10	1	17:00	380	
10	1	22:00		29
10	2	5:00		31
10	2	22:00	380	
10	3	5:00	340	21
10	4	17:00	260	
10	4	13:00		19
10	5	7:00	340	
10	5	17:00		22
10	6	7:00	310	14
10	7	7:00	190	6
10	8	7:00	160	5
10	9	7:00	140	3
10	10	7:00	87	
10	10	20:00		3
10	11	7:00		3
10	11	13:00	100	
10	12	7:00	90	2
10	13	7:00	81	2
10	14	9:00	80	2
10	15	9:00	55	
10	15	17:00		2
10	16	9:00	56	
10	16	13:00		2
10	17	9:00	38	1
10	18	9:00	39	1
10	19	9:00	39	
10	19	13:00		1
10	20	9:00	48	1
10	21	9:00	29	1
10	22	9:00	32	<1
10	23	13:00	28	<1
10	24	9:00	21	<1
10	25	9:00	29	1
10	26	9:00	16	<1
10	27	9:00	18	
10	27	16:30		1
10	28	16:00	22	1
10	29	9:00	14	<1
10	30	9:00	18	<1
10	31	9:00	15	<1
11	1	13:00	19	<1
11	2	9:00	13	<1
11	3	9:00	10	<1
11	4	9:00	11	<1
11	5	9:00	9	<1
11	6	8:00	9	<1
11	7	9:00	8	<1
11	8	9:00	8	<1
11	9	9:00	7	<1
11	10	9:00	7	<1
11	11	9:00	6	<1
11	12	9:00	4	<1
11	13	9:00	5	<1
11	14	9:00	3	<1
最大			380	57
最小			3	<1
平均			92	7
試験回数			58	58

検査項目			ジェオスミン	
採水日時			原水 (ng/L)	浄水 (ng/L)
月	日	時		
3	6	13:00	3	3
3	7	21:00	3	3
3	8	18:00	4	4
3	9	9:00	4	4
3	10	16:30	5	5
3	11	9:00	4	4
3	12	9:00	4	1
3	13	9:00	3	<1
3	14	9:00	3	<1
3	15	9:00	3	<1
3	16	9:00	3	<1
3	17	9:00	3	<1
3	18	9:00	2	<1
3	19	9:00	3	<1
3	20	9:00	2	<1
3	21	9:00	2	<1
3	22	9:00	2	<1
3	23	9:00	2	<1
3	24	9:00	2	<1
3	25	9:00	1	<1
3	26	9:00	1	<1
3	27	9:00	1	<1
3	28	9:00	1	<1
3	29	9:00	2	<1
最大			5	5
最小			1	<1
平均			3	1
試験回数			24	24

平成24年度 臨時水質検査結果

受水池前(受渡地点)

検査項目			2-MIB (ng/l)	
採水日時			測定箇所	測定値
月	日	時		
10	3	13:10	弘前受水池	27
10	3	14:45	黒石受水池	24
10	3	11:15	五所川原受水池	22
10	3	12:30	藤崎受水池	26
10	3	14:20	平川新屋受水池	26
10	3	14:10	平川金屋受水池	27
10	3	10:35	青森受水池	24
10	3	10:15	藤崎常盤受水池	27
10	3	13:45	田舎館受水池	28
10	3	12:00	板柳受水池	23
10	3	11:35	鶴田受水池	31
10	9	12:55	弘前受水池	4
10	9	14:58	黒石受水池	2
10	9	11:00	五所川原受水池	3
10	9	12:20	藤崎受水池	3
10	9	14:35	平川新屋受水池	3
10	9	14:15	平川金屋受水池	2
10	9	10:35	青森受水池	3
10	9	10:10	藤崎常盤受水池	3
10	9	13:45	田舎館受水池	3
10	9	11:55	板柳受水池	3
10	9	11:25	鶴田受水池	3
水質基準				10以下